



TYPICAL TRENCH SECTION

NOTES:

1. MINIMUM COVER TO BE 4.5' BELOW OFFICIAL STREET GRADE.
2. TRENCH WALLS TO BE SUPPORTED AS REQUIRED BY O.S.H.A.
3. PIPE SHALL BE BEDDED FROM 18" BELOW THE BOTTOM OF THE PIPE TO 12" ABOVE THE TOP OF THE PIPE.
4. TRENCH WIDTH SHALL NOT BE MORE THAN 16" NOR LESS THAN 12" WIDER THAN THE LARGEST OUTSIDE DIAMETER OF PIPE.
5. COMPACTION SHALL BE IN ACCORDANCE WITH CHAPTER 7.
6. TAPPING SADDLES REQUIRED IN AREAS WHERE THE BEDDING SECTION IS USED.

DENVER WATER

1600 West 12th Avenue • Denver, Colorado 80204
Phone (303) 628-6000 • Telecopier No. (303) 628-6851

TYPICAL TRENCH SECTION FOR PIPELINES IN DIPPING BEDROCK

Scale: NONE Date: JUNE 1995

Drawn: C.B.B. Tr: Ck:

Approved: Dr. 127 No. 35